

07.06.2021

## Kundeninformation

### Drehgeber Inkremental 2470

Der  $MTTF_d$  -Wert für unseren inkrementalen Drehgeber 2470 wurde von uns berechnet mit:

**$MTTF_d$ : 30,7 Jahre**

Alle weiteren technischen Informationen zu diesem Produkt finden sie auf unserer Homepage unter:

[Link zur Website](#)

Die Berechnung der  $MTTF_d$ -Werte wurde in Anlehnung an den Prüfgrundsatz [GS-IFA-M21](#) Kapitel 4.7 *Quantifizierung* des Instituts für Arbeitsschutz der DGUV vorgenommen. Die berechneten Werte berücksichtigen nicht die mechanische Verbindung zur Antriebswelle.

Weitere Informationen zu unseren  $MTTF_d$  -Werten finden sie auf unserer Homepage:  
[Link zur Website](#)



Arnold Hettich  
Produktmanagement

07.06.2021

## Customer Information

### Rotary Encoder Incremental 2470

The  $MTTF_d$  value for our incremental encoder 2470 was calculated by:

**$MTTF_d$ : 30,7 years**

For further technical information on this product, please visit:

[Link to our Website](#)

The  $MTTF_d$  values were calculated in accordance with chapter 4.7 *Quantification* the principles for the testing and certification of encoders [GS-IFA-M21](#) of the Institute for Occupational Safety and Health of DGUV.

The calculated values do not consider the mechanical connection to the drive shaft.

For further information on our  $MTTF_d$  –values, please visit our website:

[Link to our Website](#)



Arnold Hettich  
Product Management